

WSRC-STI-2008-00339

Revision 0

Key Words:

Rotary Filter

Filtration

Hanford

Testing of a Rotary Microfilter to Support Hanford Applications

M. R. Poirier

D. T. Herman

D. B. Stefanko

S. D. Fink

June 26, 2008

**SAVANNAH RIVER NATIONAL LABORATORY
WASHINGTON SAVANNAH RIVER COMPANY**

Savannah River Site, Aiken, SC 29808



DISCLAIMER

This report was prepared for the United States Department of Energy under Contract No. DE-AC09-96SR18500 and is an account of work performed under that contract. Reference herein to any specific commercial product, or process, does not necessarily constitute or imply endorsement, recommendation, or favoring of same by Washington Savannah River Company or by the United States Government or any agency thereof. The views and opinions of the authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Printed in the United States of America

**Prepared For
U.S. Department of Energy**

Reviews and Approvals

Authors

M. R. Poirier, SRNL, Separations Science Programs

Date

D. T. Herman, SRNL, Separations Science Programs

Date

D.B. Stefanko, SRNL, Advanced Characterization & Process Chemistry

Date

Design Check

C. A. Nash, SRNL, Separations Science Programs

Date

Customer:

D. Hamilton, CH2MHill

Date

Management

S. D. Fink, Manager, SRNL, Separations Science Programs

Date

J. C. Griffin, Manager, SRNL E&CPT Research Programs

Date

SUMMARY

Savannah River National Laboratory (SRNL) researchers are investigating and developing a rotary microfilter for solid-liquid separation applications at the Savannah River Site (SRS). Because of the success of that work, the Hanford Site is evaluating the use of the rotary microfilter for its Supplemental Pretreatment process. The authors performed rotary filter testing with a full-scale, 25-disk unit with 0.5 μ filter media manufactured by Pall Corporation using a Hanford AN-105 simulant at solids loadings of 0.06, 0.29, and 1.29 wt %.

The conclusions from this testing follow.

- The filter flux at 0.06 wt % solids reached a near constant value at an average of 0.26 gpm/ft² (6.25 gpm total).
- The filter flux at 0.29 wt % solids reached a near constant value at an average of 0.17 gpm/ft² (4 gpm total).
- The filter flux at 1.29 wt % solids reached a near constant value at an average of 0.10 gpm/ft² (2.4 gpm total).
- Because of differences in solids loadings, a direct comparison between crossflow filter flux and rotary filter flux is not possible. The data show the rotary filter produces a higher flux than the crossflow filter, but the improvement is not as large as seen in previous testing.
- Filtrate turbidity measured < 4 NTU in all samples collected.
- During production, the filter should be rinsed with filtrate or dilute caustic and drained prior to an extended shutdown to prevent the formation of a layer of settled solids on top of the filter disks.
- Inspection of the seal faces after ~ 140 hours of operation showed an expected amount of initial wear, no passing of process fluid through the seal faces, and very little change in the air channeling grooves on the stationary face.
- Some polishing was observed at the bottom of the shaft bushing. The authors recommend improving the shaft bushing by holding it in place with a locking ring and incorporated grooves to provide additional cooling.
- The authors recommend that CH2MHill Hanford test other pore size media to determine the optimum pore size for Hanford waste.

INTRODUCTION

SRNL researchers identified and tested the rotary microfilter as a technology to increase solid-liquid separation throughput.^{1,2,3,4} The testing showed significant improvement in filter flux with the rotary microfilter over the baseline crossflow filter (i.e., 2.5 – 6.5X during the scoping tests, as much as 10X in actual waste tests, and approximately 2X in pilot-scale tests).

SRNL received funding from DOE EM-21, Office of Waste Processing (formerly Office of Cleanup Technologies), to develop the rotary microfilter for high level radioactive service. The work focused on evaluating alternative rotary microfilter vendors, redesigning the equipment for radioactive service, engineering studies to evaluate the risks, determining downstream impacts, assessing costs and benefits of deploying this technology, performing actual waste and pilot-

scale testing of the technology, and evaluating alternative filter media. The work led to the decision to design, fabricate and perform testing on a full-scale rotary microfilter for potential SRS Tank Farm applications.

SRNL performed the following work to evaluate the rotary microfilter. They demonstrated flushing of the filter housing and effective removal of soluble and insoluble contaminants. They tested the rotary microfilter performance with simulated small column ion exchange feed and observed ~ 6X improvement in filter flux of a crossflow filter with similar feed. They conducted simulated sludge washing and found the rotary filter unit behaved as a continuous stirred tank reactor. They concentrated the feed to 20 wt % solids, and the filter flux was ~ 6X the flux measured with a crossflow filter at similar solids loadings.⁵

Because of the success of that testing, the Hanford Site is evaluating the use of the rotary microfilter for its Supplemental Pretreatment process.⁶ The authors received funding from DOE EM-21 to continue the development of the rotary microfilter and to evaluate its suitability for being the solid-liquid separation technology for Supplemental Pretreatment.^{7,8}

The SpinTek high shear rotary filter used in this testing has 25 filter disks covered with 0.5 μ pore size (nominal) sheet membranes (0.007 inch thick) manufactured by Pall Corporation. The filter area of each disk is 0.96 ft². The disks are physically mounted on and are hydraulically connected to a common hollow rotating shaft. The entire stack of membrane disks is enclosed within a vessel. Feed is fed into the filter vessel through the inlet on the side of the vessel wall. A pressure is set in the tank by restricting the outlet flow typically using a gate valve on the concentrate piping. This applied pressure forces liquid through the filters on the filter disk. Between each disk is a set of baffles or turbulence promoters. These turbulence promoters cause strong currents and eddies at the surface of the membrane inhibiting the formation of a filter cake. Filtrate flows through the media and along a mesh inside the disk into the hollow shaft. The filtrate then flows through the shaft to the rotary joint which allows the spinning shaft to couple to stationary piping. The concentrated slurry exits the vessel through an outlet on the bottom. Figure 1 illustrates the flow paths across the filter disks during filtration.




Figure 1. Diagram of Rotary Filter Principle of Operation

The advantage of the rotary microfilter compared to other membrane processes results from the high shear acting on the boundary layer next to the membrane. This shear greatly reduces fouling of the membrane surface and increases fluid flow through the membrane. Pressure is decoupled from the feed flow rate, allowing more control over the driving force pressure and independent control of the shear applied to the filter cake. This feature allows the direct application of shear force with a magnitude significantly greater than that available in conventional membrane systems. The membranes rotate at a tip speed of 60 ft/s in close proximity to the turbulence promoters. For comparison, previous cross-flow filter testing used axial velocities ranging from 3 to 25 ft/s.¹⁻⁴ This creates high speed currents and eddies near the membrane surface. These eddies create a great deal of turbulence at the membrane surface decreasing the buildup of filter cake on the membrane. The SpinTek rotary filter unit uses 11-inch diameter disks and typically operates with a rotational speed of 1170 rpm.

TESTING

The authors performed the rotary filter testing with a full-scale, 25-disk unit that had been used in previous testing to support the small column ion exchange and sludge washing applications for SRS.⁵ Figure 2 shows a schematic of the test system.




Figure 2. Schematic of Filter Test System

The pump used in testing was a six stage centrifugal booster pump that had been used in previous testing.⁵ It produced a flow rate of 18 – 25 gpm with a feed pressure of 60 – 100 psi. The Concentrate and Filtrate Choke valves, V1 and V2 respectively, were PVC gate valves which allowed a fine control of the pressure in the system. All isolation valves, V3 through V9, were PVC ball valves with the exception of V7, the filtrate sample valve, which was stainless steel. Pressure was measured using manual dial pressure gages, which are labeled PG1 and PG2 in Figure 2. Feed and filtrate flow were measured using Fischer Porter Magnetic flow meters and are labeled FM1 and FM2 respectively. The temperature of the process fluid was measured in the feed tank with a Type K thermocouple, indicated in the sketch as “T”. All data taken during testing was recorded by hand on data sheets. To minimize the amount of feed slurry needed, the concentrate and filtrate streams are recombined in the feed tank. The feed tank is mixed by recirculation of the concentrate and filtrate streams and by a 1 hp agitator.

Prior to the tests conducted here, the filter unit was modified by replacing the silicon carbide/silicon carbide faced John Crane Type 1 mechanical seal with a John Crane Type 28LD air cooled seal. The material of the bottom shaft bushing was changed from graphite to silicon-carbide. To prevent excessive wear on the shaft, an additional silicon carbide sleeve was added so that the contact wear surfaces at the bottom of the shaft are both silicon carbide.

The filter disks used in testing were a set of 25 un-used disks.

Personnel prepared a simulated Hanford AN-105 feed slurry containing 5 M sodium. The recipe is based on the simulant developed in 2000, but it eliminates trace RCRA metals.⁹ Table 1 shows the composition of the supernate and Table 2 shows the solids fractions of the slurry. Personnel prepared 100 gallons of supernate as follows. They added 75.6 kg of de-ionized water to a tank. Next, they added sodium aluminate, sodium hydroxide (50 wt % solution), boric acid, calcium nitrate, cesium nitrate, magnesium nitrate, potassium nitrate, zinc nitrate, sodium chloride, sodium fluoride, sodium sulfate, and potassium molybdate. They mixed the solution until all of the compounds dissolved. Next, they added sodium silicate, sodium acetate, sodium formate, sodium glycolate, sodium oxalate, and sodium phosphate, mixing the solution after the addition of each compound. They added an additional 113.4 kg of de-ionized water, and mixed the solution thoroughly. They added the sodium carbonate, and mixed thoroughly. They added the sodium nitrate and sodium nitrite, and mixed the solution thoroughly. They added an additional 146.7 kg of de-ionized water, and mixed the solution overnight.

Personnel prepared the solids fraction of the slurry as follows. They procured all of the compounds, except for sodium oxalate, with particle size less than 10 μ . The sodium oxalate was not available as less than 10 μ , so SRNL personnel ground the sodium oxalate particles using a Union Process SG-1 Attritor Mill and measured the particle size of the product with a scanning electron microscope. The analysis showed the particles to be less than 10 μ . They mixed the compounds together in the ratios shown in Table 2.

Table 1. Hanford AN-105 Supernate

<u>Compound</u>	<u>Target Concentration</u> (g/L)
NaAlO ₂	56.661
NaOH	64.461
H ₃ BO ₃	0.137
Ca(NO ₃) ₂ ·4H ₂ O	0.111
CsNO ₃	0.114
Mg(NO ₃) ₂ ·6H ₂ O	0.027
KNO ₃	9.030
Zn(NO ₃) ₂ ·6H ₂ O	0.022
NaCl	7.039
NaF	0.197
Na ₂ SO ₄	0.536
K ₂ MoO ₄	0.096
Na ₂ SiO ₃ ·9H ₂ O	1.003
NaCH ₃ COO·3H ₂ O	2.241
HCOONa	2.044
HOCH ₂ COONa	0.706
Na ₂ C ₂ O ₄	0.436
Na ₃ PO ₄ ·12H ₂ O	1.072
Na ₂ CO ₃	10.405
NaNO ₃	98.500
NaNO ₂	78.211

Table 2. Hanford AN-105 Solids

<u>Compound</u>	<u>Solids Fraction (%)</u>
Al ₂ O ₃	9.2
CaOxalate	5.0
Cr ₂ O ₃	26.0
Fe ₂ O ₃	1.1
MnO ₂	0.3
NaOxalate	52.5
NiO	0.5
SiO ₂	5.4

Personnel prepared the slurry as follows. They added 80 gallons of supernate and 226.04 g of solids to the filter feed tank to produce a 0.06 wt % solids slurry. They fed the slurry to the filter at a feed flow rate of ~25 gpm, a feed pressure of ~70 psi, and a feed temperature of ~35 °C. The filtrate pressure was ~30 psi, producing a transmembrane pressure of ~40 psi. They set the rotor speed to 1170 rpm. The filter operated for ~40 hours on day shift (i.e., ~ 8 hours per day, 5 times per week), and personnel recorded the operating parameters and filtrate flow rate during the test. The operating parameters recorded were feed flow rate, filtrate flow rate, feed pressure, concentrate pressure, filtrate pressure, temperature, and rotor speed. Motor current and output power, along with the surface temperatures of the rotary joint and mechanical seal housing were

measured at random intervals. Appendix A contains the data. They collected filtrate samples twice each day of operation to measure turbidity.

After operating for 40 hours, they added an additional 866.5 g of solids to the feed tank to produce a 0.29 wt % solids slurry. They fed the slurry to the filter at a feed flow rate of ~25 gpm, a feed pressure of ~70 psi, and a feed temperature of ~35 °C. The filtrate pressure was ~30 psi, producing a transmembrane pressure of ~40 psi. They set the rotor speed to 1170 rpm. The filter operated for ~40 hours on day shift, and personnel recorded the operating parameters and filtrate flow rate during the test. They collected filtrate samples daily to measure turbidity.

After operating for 40 hours, they added an additional 3767.38 g of solids to the feed tank to produce a 1.29 wt % solids slurry. They fed the slurry to the filter at a feed flow rate of ~25 gpm, a feed pressure of ~70 psi, and a feed temperature of ~35 °C. The filtrate pressure was ~30 psi, producing a transmembrane pressure of ~40 psi. They set the rotor speed to 1170 rpm. The filter operated for ~40 hours on day shift, and personnel recorded the operating parameters and filtrate flow rate during the test. They collected filtrate samples daily to measure turbidity.

RESULTS

Mechanical Performance and Flux

Figure 3 shows the flux with the 0.06 wt % slurry. After reaching near constant value, the filter flux averaged 0.26 gpm/ft² (6.25 gpm total). The filter reached near constant value in approximately 10 hours.




Figure 3 Flux for 0.06 wt% Insoluble Solids at TMP of 40 psi

Additional solids were added to the feed to raise the insoluble solids concentration to 0.29 wt %. **Figure 4** shows the flux with the 0.29 wt % slurry. After reaching a near constant value, the filter flux averaged 0.17 gpm/ft² (4 gpm total). The filter reached a near constant value after approximately 15 hours.




Figure 4 Flux for 0.06 wt % and 0.29 wt % Insoluble Solids at TMP of 40 psi

Figure 5 shows the flux with the 1.29 wt % slurry added. After reaching a near constant value, the filter flux averaged approximately 0.10 gpm/ft² (2.4 gpm total). The filter flux reached a near constant value after approximately 25 hours.




Figure 5 Flux for 0.06 wt %, 0.29 wt % and 1.29 wt % Insoluble Solids at TMP of 40 psi

Figure 6 compares the flux of the AN-105 simulant to the flux measured during a prior test with simulated SRS sludge. The comparison is made since both sludges contain similar compounds (e.g., metal oxides) and have relatively similar particle size (mean 1 – 5 μ). At the start of the testing with 0.06 wt % solids, the AN-105 simulant had a higher flux than the SRS sludge simulant. When we increased the solids loading to 0.29 wt %, the flux with the AN-105 simulant was initially higher. By the end of that test, the flux was approximately the same for both feed slurries. When we increased the solids loading to 1.29 wt %, the flux with SRS simulant remained approximately the same, while the flux with AN-105 decreased further.




Figure 6 Comparison of SRS and Hanford Simulant Flux Rates

Figure 7 shows a comparison of the 0.06 wt % insoluble solids loadings for the Hanford simulant and the SRS simulant.⁵




Figure 7 Comparison of Hanford and SRS Simulant Flux Rates at 0.06 wt % Insoluble Solids

Figure 8 compares the testing with the AN-105 simulant with the SRS simulant at 0.29 wt % insoluble solids.⁵ Over the course of testing both simulants reached approximately the same state-state flux of approximately 0.17 gpm per square foot of media. Total filtration rate for the filter unit was approximately 4 gpm at this solids loading.




Figure 8 Comparison of Hanford and SRS Simulant Flux Rates at 0.29 wt % Insoluble Solids

Figure 9 compares the flux of the AN-105 simulant with the SRS simulant at 1.29 wt % insoluble solids.⁵ Both simulants had approximately the same starting flux of 0.15 gpm per square foot. The flux with the AN-105 simulant continued to decay until reaching approximately 0.10 gpm per disk or 2.4 gpm of filtrate for the entire unit.




Figure 9 Comparison of Hanford and SRS Simulant Flux Rates at 1.29 wt % Insoluble Solids

Figure 10 compares the flux in this test with the flux measured during a crossflow filter test with an AN-105 simulant.¹⁰ Because the tests used different solids loadings, different filter pore size, and differences in simulant recipe, a direct comparison is not available. Comparing the rotary filter flux at 0.06 wt % solids with the crossflow filter flux at 0.5 wt % solids shows the rotary filter flux is 1.8 – 3.0 X higher. Comparing the rotary filter flux at 0.29 wt % solids with the crossflow filter flux at 0.5 wt % solids shows the rotary filter flux is 1.15 – 2.0 X higher. Comparing the rotary filter flux at 1.29 wt % solids with the crossflow filter flux at 0.5 wt % solids shows the rotary filter flux is 0.7 – 1.25 X of the flux with a crossflow filter.




Figure 10 Comparison of Flux with Rotary Filter and Crossflow Filter

Figure 11 shows the particle size distribution of the solids in the current test and in the rotary filter test using SRS sludge. Particle size was measured with a Microtrac SRA-150. The carrier fluid for the measurement was simulated salt solution (SRS salt solution for SRS sludge and AN-105 salt solution for AN-105 solids). The median particle size of the AN-105 solids was 1.49μ . The median particle size of the SRS solids was 3.32μ . In addition, the AN-105 solids had a larger fraction of particles less than 1μ . According to different filtration theories, filter flux increases with increasing particle size. The relationship is described by equation [1]

$$J = K d_p^n \quad [1]$$

where J is filter flux, K is a constant, d_p is particle size, and n is an exponent. Various filtration models have n equal to $4/3$, 2 , and 3 .¹¹ In addition, the increase in fine particles ($<1 \mu$) would provide more particles that could penetrate the filter membrane to foul the filter pores.




Figure 11. Comparison of Particle Size Data for Hanford and SRS Simulants

Figure 12 shows the particle size of the AN-105 solids from the rotary filter test and the crossflow filter test. The median particle size of the AN-105 solids in the rotary filter test was 1.49μ . The median particle size of the solids during the crossflow filter tests was 2.32μ and 2.59μ . As described above, this larger particle size would produce higher filter flux, and may explain why the rotary filter did not show as big of an improvement in filter flux as has been observed in other rotary filter versus crossflow filter tests. In addition, the feed for the rotary filter test had a larger fraction of particles less than 1μ than the feed for the crossflow filter tests.




Figure 12. Particle Size Comparison of Hanford Simulant used in Rotary and Crossflow Filters

Filtrate Clarity

Figure 13 shows the turbidity of the filtrate samples collected. All filtrate samples had turbidity less than 4 NTU.




Figure 13. Filtrate Turbidity from Rotary Filter Testing of Hanford Simulant

Disassembly and Inspection

After completion of the operational testing, personnel disassembled the filter disk stack. The disk stack was not flushed because the feed pump failed due to the packing of large (up to 2 cm) solids in the suction side of the pump (see Appendix B). A significant difference in the filter cake between the top side of the disks and the bottom side was observed. Figure 14 shows the top of a representative filter disk and Figure 15 shows the bottom side of the same filter disk (third from the bottom in the stack). The filter-cake buildup on the top side of the disk is due to the settling of the feed material when operation is complete. During testing, the filter was simply shut down at the end of the day. No draining or flushing was done. Additionally, no attempt was made to clean in the disk in-situ by dropping the TMP while maintaining the rotor speed. In previous testing, this approach was shown to improve filter flux by a small amount. The condition of the filter disks is consistent with previous observations with the top side of the disks showing a greater buildup of solids. This leads to the conclusion that the filter is better at preventing the buildup of filter cake than breaking up a filter cake that has already formed. To prevent the buildup of similar filter-cake in deployment, it is recommended that the filter be drained and flushed with filtrate or dilute caustic after shutdown.




Figure 14 Top Side of Filter Disk



Figure 15 Bottom Side of Filter Disk

Seal Wear Inspection

After disassembly was completed, the shaft seal was removed and inspected. There was no indication that any of the process fluid passed the seal. Figure 16 shows the seal rotor after the first 20 hours and 44 minutes (i.e., left photo) of operation and then after 143 hours and 28 minutes (i.e., right photo) of operation




Figure 16 Rotor Portion of Air Seal after 20 $\frac{3}{4}$ Hours (left photo) and 143 $\frac{1}{2}$ hours (right photo) of Operation

Figure 17 shows the stationary part of the seal after the first 20 hours and 44 minutes of operation and then after 143 hours and 28 minutes of operation.




Figure 17 Stationary Portion of Air Seal after 20 $\frac{3}{4}$ hours (left photo) and 143 $\frac{1}{2}$ hours (right photo) of Operation

The carbon face of the rotor is showing polishing in the area indicative of initial wear. This polishing is due to contact of the seal faces, primarily at startup and shutdown, when there is not enough velocity to cause liftoff for the faces. No evidence of the passing of process fluid was observed. Very little change to the air channeling grooves on the stationary was observed, though no depth measurements were obtained since these measurements would have required the removal of the seal stationary.

Figure 18 and Figure 19 show the condition of the bushing set at the bottom of the filter after 143 hours and 28 minutes of operation. Some polishing can be observed on the bottom of the shaft bushing as well as the receiver bushing. The shaft bushing is not supported and is held in place by a sealant. This sealant was compromised by the process fluid allowing the shaft bushing to contact the bottom of the receiver bushing. It is recommended that the shaft bushing be updated to allow it to be held in place by a retaining ring as well as incorporated grooves to allow for additional cooling flow.



Figure 18. Shaft Bushing after 143 ½ hours of Operation



Figure 19. Receiver Bushing after 143 ½ hours of Operation

Figure 20 shows the current and power draw by the filter motor during operation.




Figure 20. Filter Motor Power and Current Draw

The maximum current rating on the motor is 24.1 amps at 460 volts. No dramatic power or current increases were required as the insoluble solids loadings were increased in the process fluid.

CONCLUSIONS

The conclusions from this testing follow.

- The filter flux at 0.06 wt % solids reached a near constant value at an average of 0.26 gpm/ft² (6.25 gpm total).
- The filter flux at 0.29 wt % solids reached a near constant value at an average of 0.17 gpm/ft² (4 gpm total).
- The filter flux at 1.29 wt % solids reached a near constant value at an average of 0.10 gpm/ft² (2.4 gpm total).
- Because of differences in solids loadings, a direct comparison between crossflow filter flux and rotary filter flux is not possible. The data show the rotary filter produces a higher flux than the crossflow filter, but the improvement is not as large as seen in previous testing.
- Filtrate turbidity measured < 4 NTU in all samples collected.
- During production, the filter should be rinsed with filtrate or dilute caustic and drained prior to an extended shutdown to prevent the formation of a layer of settled solids on top of the filter disks.
- Inspection of the seal faces after ~ 140 hours of operation showed an expected amount of initial wear, no passing of process fluid through the seal faces, and very little change in the air channeling grooves on the stationary face.
- Some polishing was observed at the bottom of the shaft bushing. The authors recommend improving the shaft bushing by holding it in place with a locking ring and incorporated grooves to provide additional cooling.
- The authors recommend that CH2MHill Hanford test other pore size media to determine the optimum pore size for Hanford waste.

REFERENCES

1. M. R. Poirier, "Evaluation of Solid-Liquid Separation Technologies to Remove Sludge and Monosodium Titanate from SRS High Level Waste", WSRC-TR-2000-00288, Rev. 0, August 16, 2000.
2. M. R. Poirier, "Filtration Systems, Inc., Report for SRS SpinTek Rotary Microfilter Testing", WSRC-TR-2001-00214, Rev. 0, May 4, 2001.
3. D. T. Herman, M. R. Poirier, and S. D. Fink, "Testing of the SpinTek Rotary Microfilter Using Actual Waste", WSRC-TR-2003-00030, Rev. 1, December 2003.
4. M. R. Poirier, D. T. Herman, S. D. Fink, R. Haggard, T. Deal, C. Stork, and V. Van Brunt, "Pilot-Scale Testing of a SpinTek Rotary Microfilter with SRS Simulated High Level Waste", WSRC-TR-2003-00071, February 3, 2003.
5. D. T. Herman, M. R. Poirier, and S. D. Fink, "Testing and Evaluation of the Modified Design of the 25-Disk Rotary Microfilter", WSRC-STI-2006-00073, Rev. 0, August 2006.
6. M.G. Thien, M.E. Johnson, D.W. Reberger, R.D. Williamson, C.M. Musick, and M.D. Roupe, "Evaluation of Starting the Waste Treatment and Immobilization Plant(WTP) Low Activity Waste LAW) Facility First", RPP-29981, Rev. 0, July 2006, CH2MHill Hanford Group, Inc., Richland , WA, June 2006.
7. K. Gerdes, "Rotary Microfilter for Hanford Tank Waste", TTP SR-07-1101, March 18, 2008.
8. M. R. Poirier, D. T. Herman, D. B. Stefanko, S. D. Fink, "Task Technical and Quality Assurance Plan for the Testing of the Rotary Microfilter to Support Hanford Applications", WSRC-RP-2007-00794, Rev 0, September 6, 2007.
9. R. E. Eibling and C. A. Nash, "Hanford Waste Simulants Created to Support the Research and Development on the River Protection Project – Waste Treatment Plant", WSRC-TR-2000-00338, February 2001.
10. M. R. Duignan, "Final Report: Pilot-scale Cross-flow Ultrafiltration Test Using a Hanford Site Tank 241-AN-105 Waste Simulant – Envelope A + Entrained Solids", BNF-003-98-0221, Rev. 0, February 23, 2000.
11. R. A. Peterson, C. A. Nash, and D. J. McCabe, "Correlation of Filtrate Flow Rate for Irradiated and Unirradiated Tetraphenylborate Slurries", WSRC-MS-95-0448.

Rotary Microfilter Data Sheet

Date: 12/10/07

P6J P52

Time (hh:mm)	Tank Level (gal)	Temp (°F)	Conc. Press (psi)	Filtrate Press (psi)	Feed Flow (m³/h)	Filtrate Flow (m³/h)	Rotar Speed (RPM)	Insol Solids (wt %)	Comments	Observer
10:05	20	81.2	45	2.2	12.30	5.61	600	40%	Rotar Joint 77.3°F	
10:16	30	91.0	43	2.2	12.30	5.40	600	40%	10min Seal-91.5°F Joint-97.2	
									STOPPED	
11:32	30	94.0	41.5	2.1	11.52	3.04	600	40%	Joint-93.0 Seal-97.0	
11:38	30	85.6	41.0	2.1	11.53	6.07	600	40%	Seals-15.3 Joint-83.0 Seal-97.5	
									Stopped	
15:07	30	91.8	38.0	15.5	12.16	5.23	60.0	40%	water 94.5°F Temp @ Rotar Joint	MP
15:30	30	98.1	50.0	19.5	11.95	6.30	60.0	40%	water 95.9°F Temp @ Seal	MP
									96°F Rotar Joint 119°F Inlet	MP
10:50	30	80.0	50.0	22.0	11.91	5.82	60.0	40%	Rotar Joint 79°F Inlet 79.5	MP
11:07	30.0	101.3	50.0	18.0	11.52	6.47	60.0	40%	151 Amps	
11:15	30.0	92.0	70.0	35.0	11.69	6.22	60.0	40%	Joint 96.5 Inlet 93.5	MP
11:34	30.0	94.6	70.0	33.0	11.50	6.40	60.0	40%	Joint 91.5 Inlet 94.5	MP
11:59	30.0	94.6	70.0	33.0	11.50	6.40	49.6	40%	Joint 91.5 Seal 91.5	MP
	30.0		63.0	31.0	11.50	6.10	60.0	40%	Seal 91.5	MP

12.11

25 Dair Rotary Filter Data Sheet													
Date	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc PG-1 (PSI)	Filterate PG-2 (psi)	Feed Flow (mA)	Filterate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments	Recorded by
12-19-07													
13:10	70	0.06	81.6	70	3.0	148	4.71	60.0	69.5	73.0	19.5	Final light level of 80 gal. solids - 29% moisture	SWP
13:25	70	0.06	81.2	70	3.2	149	4.90	60.0	71.5	73.0	19.0		SWP
13:40	70	0.06	81.9	71	3.1	148	5.03	60.0	71.5	73.0	18.7		SWP
13:50												Polled about 30 seconds	SWP
14:00												Added 0.1% water to seeds	SWP
14:03	↓	↓	41.6	72	5.7	137	4.30	60	118.5	105	18.5		SWP
14:05	↓	↓	43.4	70	2.8	147	5.34	60	118.5	105	18.3		SWP
14:10	70	0.06	81.5	71	3.0	148	5.05	60	118.5	105	18.3		SWP
14:15	↓	↓	104.3	72	3.0	149	5.31	60	100.5	97.0	18.1		SWP
14:20	70	0.06	81.2	72	3.0	148	5.52	60	100.5	97.0	18.0		SWP
14:27	70	↓	92.9	70	3.1	148.5	5.32	60	100.0	100.0	18.0		SWP
14:30	↓	↓	92.9	70	3.0	148.2	5.18	60	100.0	100.0	18.0		SWP
14:30	70	0.06	82.9	70	3.0	147	5.18	60	100.0	100.0	18.1		SWP
14:40	↓	↓	93.2	70	3.0	147	5.12	60	100.0	100.0	18.3		SWP
14:50	↓	↓	93.2	70	3.0	148	5.32	60	94	95	18.1		SWP
14:53	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
14:56	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
14:57	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
14:58	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
14:59	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:00	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:01	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:02	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:03	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:04	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:05	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:06	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:07	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:08	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:09	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:10	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:11	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:12	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:13	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:14	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:15	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:16	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:17	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:18	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:19	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:20	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:21	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:22	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:23	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:24	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:25	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:26	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:27	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:28	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:29	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:30	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:31	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:32	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:33	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:34	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:35	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:36	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:37	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:38	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:39	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:40	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:41	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:42	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:43	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:44	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:45	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:46	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:47	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:48	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:49	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:50	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:51	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:52	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:53	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:54	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:55	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:56	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:57	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:58	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
15:59	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:00	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:01	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:02	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:03	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:04	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:05	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:06	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:07	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:08	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:09	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:10	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:11	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:12	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:13	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:14	↓	↓	93.6	70	3.0	147	5.14	60	94	95	18.1		SWP
16:15	↓	↓	93.6	70	3.0	1							

25 Disk Rotary Filter Data Sheet												
Date:	12-20-07											
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc. PG-1 (PSI)	Filtrate PG-2 (psi)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments
0800	70.0	0.06	81.1	70.0	30.0	1220	520	60.0	78.5	82.0	18.7	Mixer Speed = 40
0810	70.0	0.06	81.1	70.0	30.0	1220	520	60.0	78.5	82.0	18.7	Mixer Speed = 40
0815	70.0	0.06	81.1	70.0	30.0	1220	542	60.0	86.5	82.5	18.4	
0830	70.0	0.06	81.1	70.0	30.0	1175	547	60.0	92.0	93.0	19.4	Mixer appears to have extracted air
0845	70.0	0.06	81.1	70.0	30.0	1191	547	60.0	95.0	96.0	19.3	
0900	70.0	0.06	81.1	70.0	30.0	1182	547	60.0	95.5	96.5	18.3	
0915	70.0	0.06	81.1	70.0	30.0	1173	543	60.0	97.0	97.0	18.3	output power 12 kw
0930	70.0	0.06	81.1	70.0	30.0	1172	543	60.0	97.0	97.0	18.3	
0945	70.0	0.06	81.1	70.0	30.0	1202	535	60.0	98.5	98.5	18.3	
1000	70.0	0.06	81.1	70.0	30.0	1183	534	60.0	99.0	99.0	18.3	
1015	70.0	0.06	81.1	70.0	30.0	1201	536	60.0	97.0	97.0	18.3	
1030	70.0	0.06	81.1	70.0	30.0	1187	542	60.0	98.5	98.5	18.3	
1045	70.0	0.06	81.1	70.0	30.0	1201	545	60.0	97.5	97.5	18.4	
1100	70.0	0.06	81.1	70.0	30.0	1199	541	60.0	98.0	98.0	18.3	
1115	70.0	0.06	81.1	70.0	30.0	1203	544	60.0	96.5	96.5	18.3	

25 Disk Rotary Filter Data Sheet												
Date:	1-2-08											
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc Press PG-1 (PSI)	Filtrate Press PG-2 (PSI)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments
11:35	760	0.06	617	0.8	30	1161	4.92	60	67.0	71.0	19.7	Mixer found up pulled Sample 511 make
11:40	760	0.06	603	70	30	1161	5.47	60	67	84.5	18.8	
12:00	760	0.06	613	70	30	1137	5.41	60.0	62.5	82.0	18.4	
12:15	760	0.06	624	70	32	1141	5.34	60.0	62.5	82.5	18.4	
12:30	760	0.06	624	72	32	1141	5.35	60.0	65.5	85.0	18.4	
12:45	760	0.06	645	70	30	1182	5.41	60.0	73.5	94.8	18.8	
13:00	760	0.06	645	70	30	1187	5.41	60.0	93.5	94.3	19.2	
13:15	760	0.06	650	91	30	1187	5.42	60.0	95.0	95.0	18.8	
13:30	760	0.06	651	70	30	1173	5.41	60.0	95.0	95.0	18.8	
13:45	760	0.06	645	70	30	1182	5.35	60.0	95.5	95.5	18.8	
14:00	760	0.06	649	71	31	1183	5.34	60.0	94.5	93.5	18.2	
14:15	760	0.06	645	70	30	1198	5.35	60.0	95	95.5	18.3	
14:30	760	0.06	65.1	70	30	1176	5.32	60.0	96.0	96.0	18.2	
14:45	760	0.06	649	70	31	1183	5.47	60.0	95.0	93.0	18.3	
15:00	760	0.06	649	71	32	1174	5.47	60.0	96.5	96.5	17.7	
15:15	760	0.06	646	71	30	1185	5.47	60.0	96.5	96.0	18.2	
15:30	760	0.06	646	71	30	1190	5.54	60.0	97.0	97.0	18.3	
15:45	760	0.06	650	71	31	1193	5.46	60.0	96.0	97.5	18.3	
16:01	760	0.06	65.1	71	31	1179	5.39	60.0	92.5	96.5	18.4	

15:05 Effluent sample pulled

Recorded by

25 Disk Rotary Filter Data Sheet													
Date:	1-3-08												
Time	Tank Level	Solids Loading (wt %)	Temp (F)	Conc. Press PG-1 (psi)	Filterate Press PG-2 (psi)	Feed Flow (mA)	Filterate Flow (mA)	Rotor Speed (rpm)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments	Recorded by
7:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2	HY @ 67°F	Soren
7:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
8:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
8:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
8:30	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
8:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
9:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
9:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
9:30	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
9:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
10:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2	Pulverized Sulfate Sample	Soren
10:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
10:30	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
10:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
11:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
11:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
11:30	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
11:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
12:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
12:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
12:30	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2	Long Trip to ~ 3500' Sample Station 15/Trade (1800)	Soren
12:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
13:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
13:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
13:30	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
13:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
14:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
14:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
14:30	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
14:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
15:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
15:15	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
15:30	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
15:45	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		
16:00	70	0.06	90.6	70	30	11.81	5.33	60.0	95.5	98.0	18.2		

25 Disk Rotary Filter Data Sheet														
Date:	1-28-2005													
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc. Press PG-1 (PSI)	Filtrate Press PG-2 (psi)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Joint Temp (F)	Motor Current (amps)	Comments	Recorded by	
0730	67	0.06	74	70	30	11.96	9.25	60	94.5	93.5	18.8	Start UP Comments add brine to wash pan Pulled Filtrate Sample	DTH	
0749	67	0.06	73	70	31	11.94	9.20	60	94.5	93.5	18.6			
0800	68	0.06	74	70	30	11.76	9.21	60	94.5	93.0	18.5			
0815	68	0.06	74	70	30	11.93	9.34	60	94.5	93.5	18.8			
0830	67	0.06	75	70	30	11.90	9.35	60	94.5	93.5	18.8			
0849	67	0.06	75	71	30	11.90	9.37	60	94.5	93.5	18.8			
0900	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8			
0915	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8			
0930	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8			
0949	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8			
1000	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1015	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1030	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1049	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1100	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1115	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1130	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1149	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1200	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1215	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1230	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1249	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1300	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1318	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1338	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1400	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1431	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
1445	67	0.06	75	70	30	11.90	9.37	60	94.5	93.5	18.8		DTH	
0835	65	0.06	71	70	30	11.85	9.35	60	87	91	18.8		DTH	
1415	68	0.06	72	71	31	11.85	9.24	60	71.5	91.5	18.7		DTH	

25 Disk Rotary Filter Data Sheet												
Date:	1-29-08											
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc. Press PG-1 (PSI)	Filtrate Press PG-2 (psi)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Recorded by
0741	63	0.06	78	30	30	11.94	5.94	60	69	95.3	19.1	Start UP
0800	63	0.06	79	30	30	11.79	5.13	60	80.3	99	19.5	Comments Start UP
0815	63	0.06	94	30	30	11.71	5.16	60	91.0	98.5	19.7	
0830	63	0.06	94	30	30	11.73	5.17	60	92.5	98.5	19.7	
0845	63	0.06	94	30	30	11.74	5.17	60	93.5	98.5	19.7	
0900	63	0.06	94	30	30	11.74	5.17	60	94.5	98.5	19.7	
0915	63	0.06	94	30	30	11.74	5.17	60	95.5	98.5	19.7	
0930	63	0.06	94	30	30	11.74	5.17	60	96.5	98.5	19.7	
0945	63	0.06	94	30	30	11.74	5.17	60	97.5	98.5	19.7	
1000	63	0.06	94	30	30	11.74	5.17	60	98.5	98.5	19.7	
1015	63	0.06	94	30	30	11.74	5.17	60	99.5	98.5	19.7	
1030	63	0.06	94	30	30	11.74	5.17	60	100.5	98.5	19.7	
1045	63	0.06	94	30	30	11.74	5.17	60	101.5	98.5	19.7	
1100	63	0.06	94	30	30	11.74	5.17	60	102.5	98.5	19.7	
1115	63	0.06	94	30	30	11.74	5.17	60	103.5	98.5	19.7	
1130	63	0.06	94	30	30	11.74	5.17	60	104.5	98.5	19.7	
1145	63	0.06	94	30	30	11.74	5.17	60	105.5	98.5	19.7	
1200	63	0.06	94	30	30	11.74	5.17	60	106.5	98.5	19.7	
1215	63	0.06	94	30	30	11.74	5.17	60	107.5	98.5	19.7	
1230	63	0.06	94	30	30	11.74	5.17	60	108.5	98.5	19.7	
1245	63	0.06	94	30	30	11.74	5.17	60	109.5	98.5	19.7	
1300	63	0.06	94	30	30	11.74	5.17	60	110.5	98.5	19.7	
1315	63	0.06	94	30	30	11.74	5.17	60	111.5	98.5	19.7	
1330	63	0.06	94	30	30	11.74	5.17	60	112.5	98.5	19.7	
1345	63	0.06	94	30	30	11.74	5.17	60	113.5	98.5	19.7	
1418	63	0.06	94	30	30	11.74	5.17	60	114.5	98.5	19.7	
1432	63	0.06	94	30	30	11.74	5.17	60	115.5	98.5	19.7	
1500	63	0.06	94	30	30	11.74	5.17	60	116.5	98.5	19.7	
1534	63	0.06	94	30	30	11.74	5.17	60	117.5	98.5	19.7	
1600	63	0.06	94	30	30	11.74	5.17	60	118.5	98.5	19.7	
1631	63	0.06	94	30	30	11.74	5.17	60	119.5	98.5	19.7	
1701	63	0.06	94	30	30	11.74	5.17	60	120.5	98.5	19.7	
1730	63	0.06	94	30	30	11.74	5.17	60	121.5	98.5	19.7	
1800	63	0.06	94	30	30	11.74	5.17	60	122.5	98.5	19.7	
1831	63	0.06	94	30	30	11.74	5.17	60	123.5	98.5	19.7	

Pulled Filtrate Sample

Pulled Filtrate Sample

12.36 KW
17.73 KW
175.4 Amps
175.4 Amps
18.5

25 Disk Rotary Filter Data Sheet												
Date:	1/31/08											
Time (hr:min)	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc. Press PG-1 (PSI)	Filtrate Press PG-2 (psf)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments
07:33	65	0.06	80	70	30	11.56	8.94	60	72	78.5	17.2	Recorded by DNY Subm DNY DNY DNY DNY DNY DNY DNY DNY
07:48			82	70	30	11.57	9.19		86.9	93.9	18.7	
08:15			82	70	30	11.86	9.24		86.5	97.5	18.5	
08:30			82	70	30	11.87	9.24		87	96.5	18.7	
09:00			82	70	30	11.88	9.25		87.9	94.9	18.5	
09:18			82	70	30	11.89	9.25		88.5	93.9	18.5	
09:30			82	70	30	11.86	9.23		88.4	94.0	18.5	
10:00			82	70	30	11.87	9.17		86.0	94.8	18.5	
10:30			82	70	30	11.88	9.23		86.0	94.1	18.5	
10:45			82	70	30	11.89	9.23		86.5	94.0	18.4	
11:00			82	70	30	11.89	9.21		86.5	94.0	18.4	
11:15			82	70	30	11.88	9.17		86.1	93.5	18.4	
11:30			82	70	30	11.88	9.17		86.1	93.5	18.4	
11:45			82	70	30	11.87	9.17		86.0	93.5	18.4	
12:00			82	70	30	11.87	9.20		86.0	93.5	18.4	
12:15			82	70	30	11.87	9.21		86.0	93.5	18.4	
12:30			82	70	30	11.87	9.21		86.0	93.5	18.4	
12:45			82	70	30	11.87	9.19		86.0	93.5	18.4	
13:00			82	70	30	11.87	9.09		86.5	95.0	18.5	
13:30			82	70	30	11.81	9.14		87.0	96.0	18.4	
14:03			82	70	30	11.79	9.06		88.5	97.5	19.3	
14:45			82	70	30	11.79	9.02		88.5	97.5	19.4	
15:10			82	70	30	11.73	9.04		88.5	97	18.5	
15:40			82	70	30	11.72	9.13		88.5	96.5	18.6	
16:15			82	70	30	11.81	9.05		87	96	18.5	
16:58			82	70	30	11.75	9.09		87.5	98.5	18.4	
17:39			82	70	30	11.74	9.12		87.5	97.5	18.4	
18:06			82	70	30	11.73	9.04		87.5	97.5	18.4	
18:33			82	70	30	11.72	9.15		87.5	97.0	18.4	

12.22 KC
12.91 KC
run at medium flow rate
DNY - sample 18:20

25 Disk Rotary Filter Data Sheet													
Date:	1-31-08												
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc PG-1 (PSI)	Filtrate PG-2 (gal)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments	Recorded by
0800	68	206	77	70	30	1190	867	60	87.5	72.5	19.1	Started Run	Soren
0815			91	70	30	1190	897		87.5	73.0	18.7		Soren
0830			93	70	30	1190	917		87.5	74.0	18.6		Soren
0845			93	70	30	1190	900		87.5	74.0	18.6		Soren
0900			93	70	30	1190	900		87.5	74.0	18.6		Soren
0915			93	70	30	1190	900		87.5	74.0	18.6		Soren
0930			93	70	30	1190	900		87.5	74.0	18.6		Soren
0945			93	70	30	1190	900		87.5	74.0	18.6		Soren
1000			93	70	30	1190	900		87.5	74.0	18.6		Soren
1015			93	70	30	1190	900		87.5	74.0	18.6		Soren
1030			93	70	30	1190	900		87.5	74.0	18.6		Soren
1045			93	70	30	1190	900		87.5	74.0	18.6		Soren
1100			93	70	30	1190	900		87.5	74.0	18.6		Soren
1115			93	70	30	1190	900		87.5	74.0	18.6		Soren
1130			93	70	30	1190	900		87.5	74.0	18.6		Soren
1145			93	70	30	1190	900		87.5	74.0	18.6		Soren
1213			93	70	30	1190	900		87.5	74.0	18.6		Soren
1230			93	70	30	1190	900		87.5	74.0	18.6		Soren
1245			93	70	30	1190	900		87.5	74.0	18.6		Soren
1300			93	70	30	1190	900		87.5	74.0	18.6		Soren
1315			93	70	30	1190	900		87.5	74.0	18.6		Soren
1330			93	70	30	1190	900		87.5	74.0	18.6		Soren
1345			93	70	30	1190	900		87.5	74.0	18.6		Soren
1400			93	70	30	1190	900		87.5	74.0	18.6		Soren
1415			93	70	30	1190	900		87.5	74.0	18.6		Soren
1430			93	70	30	1190	900		87.5	74.0	18.6		Soren
1445			93	70	30	1190	900		87.5	74.0	18.6		Soren
1500			93	70	30	1190	900		87.5	74.0	18.6		Soren
1535			93	70	30	1190	900		87.5	74.0	18.6		Soren
1600			93	70	30	1190	900		87.5	74.0	18.6		Soren
1635			93	70	30	1190	900		87.5	74.0	18.6		Soren
1700			93	70	30	1190	900		87.5	74.0	18.6		Soren

6

25 Disk Rotary Filter Data Sheet												
Date:	2/1/08											
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc. PG-1 (PSI)	Filtrate PG-2 (psi)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments
0945	68	0.24	73	30	30	1191	8.95	6.0	71.5	33.5	14.6	13.11 kW
0946			71	31	31	1191	8.92		71.5	33.5	14.6	Added solids to 0.25% DTH
0948			70	30	30	1180	8.91		71.5	33.5	14.6	
0949			70	30	30	1180	8.91		71.5	33.5	14.6	
0950			70	30	30	1180	8.91		71.5	33.5	14.6	
0952			70	30	30	1180	8.91		71.5	33.5	14.6	
1003			70	30	30	1180	8.91		71.5	33.5	14.6	
1048			70	30	30	1180	8.91		71.5	33.5	14.6	
1107			71	30	30	1181	8.93		71.5	33.5	14.6	
1113			71	30	30	1181	8.93		71.5	33.5	14.6	
1130			70	30	30	1173	8.92		71.5	33.5	14.6	
1145			72	30	30	1181	8.93		71.5	33.5	14.6	
1201			75	30	30	1181	8.93		71.5	33.5	14.6	
1258			75	30	30	1181	8.93		71.5	33.5	14.6	
1315			78	30	30	1181	8.93		71.5	33.5	14.6	
1335			76	30	30	1181	8.93		71.5	33.5	14.6	
1427			91	30	30	1181	8.93		71.5	33.5	14.6	
1500			70	30	30	1181	8.93		71.5	33.5	14.6	
1558			75	30	30	1181	8.93		71.5	33.5	14.6	
1640			75	30	30	1181	8.93		71.5	33.5	14.6	
1725			76	30	30	1181	8.93		71.5	33.5	14.6	
1820			96	30	30	1181	8.93		71.5	33.5	14.6	
1844			96	30	30	1181	8.93		71.5	33.5	14.6	

Pulled Filtrate and feed
 12.5V KC
 13.08 KC
 5.1 min
 13.11 kW
 Added solids to 0.25% DTH
 Pulled Filtrate Sample
 Vibration measurement using the 1181
 13.08 KC
 13.11 kW
 Added solids to 0.25% DTH
 13.08 KC
 13.11 kW
 Added solids to 0.25% DTH

25 Disk Rotary Filter Data Sheet													
Date:	2-5-07												
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc PG-1 (PSI)	Filtrate PG-2 (psi)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (rpm)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments	Recorded by
0746	68	0.29	53	70	30	1152	717	60	76	93.5	18.9	Started run	Sum
0800			53	70	30	1143	715		76	92.8	19.0		Sum
0813			53	70	30	1151	717		76	93.2	19.0		Sum
0830			53	70	30	1151	717		76	93.5	19.3		Sum
0849			53	70	30	1151	718		76	94.0	19.2		Sum
0900			53	70	30	1151	718		76	94.0	19.2		Sum
0913			53	70	30	1151	718		76	94.0	19.2		Sum
0930			53	70	30	1151	718		76	94.0	19.2		Sum
0949			53	70	30	1151	718		76	94.0	19.2		Sum
1000			53	70	30	1151	718		76	94.0	19.2		Sum
1015			53	70	30	1151	718		76	94.0	19.2		Sum
1030			53	70	30	1151	718		76	94.0	19.2		Sum
1045			53	70	30	1151	718		76	94.0	19.2		Sum
1100			53	70	30	1151	718		76	94.0	19.2	STOPPED RUN	Sum
1525			90	70	30	1185	761		90.5	50.5	18.8		Sum
1545			93	70	30	1177	761		91.5	55	18.2		Sum
1615			15	72	31	1171	769		99	58.5	18.6		Sum
1650			12	70	30	1163	759		95.5	102	18.5		Sum
1720			93	70	30	1172	751		100	100.5	19.2		Sum
1745			95	70	30	1180	752		95	100.5	18.9		Sum

25 Desk Rotary Filter Data Sheet													
Date	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc. PG-1 (PSI)	Filterate PG-2 (gal)	Feed Flow (mA)	Filterate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments	Recorded by
0706	68	0.29	95	70	30	1187	745	60	94.5	72.6	18.8	Started Filter	Susan
0719			92	70	30	1173	716.1		94.3	93.0	18.7		Susan
0730			93	70	30	1191	715.3		94.5	94.0	19.0		Susan
0742			95	70	30	1178	715.3		96.5	94.0	19.8		Susan
0743			95	70	30	1179	715.9		99.0	96.5	19.9		Susan
0730			93	70	30	1150	715.6		90.5	90.0	19.1		Susan
0740			93	70	30	1163	718.1		90.5	90.0	19.1		Susan
0719			94	70	30	1153	715.1		92.5	90.0	18.5		Susan
0730			93	70	30	1153	715.1		92.5	90.0	18.5		Susan
0745			93	70	30	1181	715.1		91.0	90.0	18.5		Susan
1000			94	70	30	1180	715.2		91.0	90.0	18.5		Susan
1030			94	70	30	1183	715.3		91.5	90.0	18.5		Susan
1049			93	70	30	1192	715.1		96.5	95.0	18.5		Susan
1100			93	70	30	1191	714.8		91.0	91.0	18.5		Susan
1115			95	70	30	1180	715.0		96.0	94.5	18.5		Susan
1130			95	70	30	1183	715.0		95.5	94.0	18.5		Susan
1145			95	70	30	1181	715.1		96.5	94.5	18.5		Susan
1200			93	70	30	1172	714.0		96.5	94.5	18.5		Susan
1210			95	70	30	1180	714.0		96.5	94.5	18.5	12.25 KL	Susan
1304			95	70	30	1181	714.1		96.5	94.5	18.0		Susan
1330			95	70	30	1186	714.1		96.5	94.5	18.5		Susan
1400			95	70	30	1173	714.0		96	94	18.5		Susan
1530			95	70	30	1177	714.3		97.5	100	18.5		Susan
1725			95	70	30	1173	714.3		98	98.5	18.7		Susan
1734			95	70	30	1171	713.1		95.5	97.5	18.3		Susan
1815			95	70	30	1172	713.2		98	100.5	18.5		Susan
1835			95	70	30	1174	712.8		97	97.5	18.8		Susan

25 Disk Rotary Filter Data Sheet													
Date:	2/2/08												
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc PG-1 (PSI)	Filtrate PG-2 (gal)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments	Recorded By
8:50	64	0.74	82	70	30	11.9%	2.14	60	77	52.5	19.0	12.37 K U	DDT
8:55			44	70	30	11.6	2.18		91	43.5	19.0	12.55 K U	DDT
8:58			95	70	30	11.8	4.34		99	39.5	19.0		DDT
9:00			96	70	30	11.71	4.35		100	101	18.8	12.32 K U	DDT
9:05			95	70	30	11.67	7.30		92	97	18.5		DDT
10:00			93	70	30	11.94	7.37		93	95.0	18.5	put down	DDT
10:05			92	70	30	11.97	7.33		91.8	96.0	18.6	Started run	DDT
10:30			95	70	30	11.95	7.36		99	96.0	19.1		DDT
10:45			92	70	30	11.90	7.36		93.3	96.0	19.1		DDT
11:00			92	70	30	11.76	7.38		100.0	96.0	19.1		DDT
11:15			95	70	30	11.31	7.37		95.0	96.0	18.5		DDT
11:30			95	70	30	11.80	7.39		95.0	93.5	18.5		DDT
11:45			91	70	30	11.80	7.35		96.0	94.8	18.5		DDT
12:00			96	70	30	11.8	7.33		97.0	96.5	18.5		DDT
12:15			95	70	30	11.31	7.32		101.0	96.5	19.6		DDT
12:30			97	70	30	11.31	7.32		94.0	96.5	19.0		DDT
13:00			97	70	30	11.82	7.32		95.5	100.5	18.5		DDT
13:15			95	70	30	11.73	7.26		94	96	18.4	12.24 K U	DDT
13:30			95	70	30	11.91	7.18		96	98.5	18.4		DDT
13:45			90	70	30	11.83	7.25		99	101.5	18.5		DDT
14:00			95	70	30	11.75	7.8		98.5	100.5	18.5		DDT
14:15			95	70	30	11.81	7.44		96.5	99	18.5	12.29 K U	DDT
14:30			95	70	30	11.81	7.22						DDT
14:45													DDT
15:00													DDT
15:15													DDT
15:30													DDT
15:45													DDT
16:00													DDT
16:15													DDT
16:30													DDT
16:45													DDT
17:00													DDT
17:15													DDT
17:30													DDT
17:45													DDT
18:00													DDT
18:15													DDT
18:30													DDT
18:45													DDT
19:00													DDT
19:15													DDT
19:30													DDT
19:45													DDT
20:00													DDT

25 D-Sk Rotary Filter Data Sheet													
Date	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Comp. Press (PSI)	Filtrate Press (PSI)	Feed Flow (mA)	Filter Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Roller Temp (F)	Motor Current (amps)	Comments	Recorded by
10/5	69	0.29	91	70	30	1191	722	60	960	945	18.4		Seema Zoran
10/30			91	70	30	1191	713		930	945	18.4		Seema Zoran
10/26			91	70	30	1191	720		935	945	18.4		Seema Zoran
11/02			91	70	30	1181	720		935	945	18.4		Seema Zoran
11/30			91	70	30	1190	724		930	945	18.4		Seema Zoran
11/45			91	70	30	1191	732		930	945	18.4		Seema Zoran
13/02			91	70	30	1191	731		935	945	18.4		Seema Zoran
12/13			91	70	30	1191	731		935	945	18.4		Seema Zoran

25 Disk Rotary Filter Data Sheet												
Date:	2-11-08											
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc. Press PG-1 (PSI)	Filtrate Press PG-2 (psi)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments
0718	6.5	1.29	72	70	70	1193	6.81	60	60.0	72.0	19.6	Started run 12.52 KW
0831			83	70	70	1191	6.69		60.0	72.0	19.6	
0845			87	70	70	1196	6.95		60.0	72.0	19.6	Pulled Feed Sample
0900			91	70	70	1195	6.89		60.0	72.0	19.2	
0914			93	70	70	1189	6.93		60.0	72.0	19.2	Pulled Filtrate Sample
0930			93	70	70	1191	6.92		60.0	72.0	19.6	
0949			95	70	70	1198	6.73		60.0	72.0	19.6	Stopped Run
1000			95	70	70	1190	6.56		60.0	72.0	19.6	
1015			93	70	70	1192	6.96		60.0	72.0	19.6	Stopped Run
1030			91	70	70	1193	6.96		60.0	72.0	19.6	
1043			93	70	70	1191	6.94		60.0	72.0	19.7	Stopped Run
1100			93	70	70	1194	6.92		60.0	72.0	19.8	
1115			92	70	70	1193	6.93		60.0	72.0	19.8	Stopped Run
1130			90	70	70	1190	6.89		60.0	72.0	19.8	
1145			90	70	70	1190	6.70		60.0	72.0	19.5	Stopped Run
1200			90	70	70	1190	6.91		60.0	72.0	19.1	
1215			97	70	70	1190	6.43		60.0	72.0	19.1	STOPPED RUN
1229			91	70	70	1196	7.00		80	80.5	19.0	Stopped Run
1517			91	70	70	1186	6.75		80	80.5	18.9	
1605			95	70	70	1198	6.89		85	85.0	18.9	Stopped Run
1617			96	70	70	1185	6.89		85	85.0	18.6	
1836			93	70	70	1189	7.00				18.7	Stopped Run
1945			95	70	70	1193	7.10				18.7	


25 Disk Rotary Filter Data Sheet												
Date:	2-12-08											
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Conc. PG-1 (PSI)	Filtrate PG-2 (psi)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments
0930	6.5	1.29	90	90	30	1191	6.56	60	92	94	19.1	Started run
0945			90	90	30	1197	6.57	93.5	90.5	19.0	Comments	
0960			92	90	30	1194	6.67	91.5	92.5	19.4		Started run
0915			94	90	30	1194	6.60	93	93.0	19.6	Pulled filtrate sample	
0930			94	90	30	1194	6.60	93.0	93.5	19.7		Started run
0945			93	90	30	1193	6.59	93.0	94.0	19.7	Started run	
1013			93	90	30	1191	6.63	93.5	94.0	19.5		Started run
1030			95	90	30	1187	6.60	94.5	94.5	19.5	Started run	
1045			95	90	30	1187	6.59	94.5	94.5	19.5		Started run
1100			95	90	30	1184	6.59	94.5	94.5	19.5	Started run	
1115			93	90	30	1180	6.59	94.5	94.5	19.4		Started run
1130			93	90	30	1180	6.59	94.5	94.5	19.4	Started run	
1145			93	90	30	1180	6.59	94.5	94.5	19.4		Started run
1300			94	90	30	1180	6.59	94.5	94.5	19.4	Started run	
1315			94	90	30	1181	6.59	94.5	94.5	19.4		Started run
1345			94	90	30	1181	6.48	94.5	94.5	19.3	Started run	
1400			94	90	30	1183	6.46	94.5	94.5	19.3		Started run
1415			94	90	30	1181	6.44	94.5	94.5	19.3	Started run	
1430			94	90	30	1180	6.46	94.5	94.5	19.6		Started run
1440			93	90	30	1182	6.49	94.5	94.5	19.7	Started run	
1515			93	90	30	1180	6.34	94.5	94.5	18.6		Started run
1530											Shut down	

25 Disk Rotary Filter Data Sheet												
Date:	2/13/08											
Time	Tank Level (gal)	Solids Loading (wt %)	Temp (F)	Press PG-1 (PSI)	Press PG-2 (psi)	Feed Flow (mA)	Filtrate Flow (mA)	Rotary Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments
8:14	65	1.77	80	70	30	1173	614	60	78.5	80.5	15.3	detached coupling alignment 12.96 KW
9:30			93	70	30	1181	634	60	77	78.5	18.8	
10:00			94	70	30	1180	637	60	77	78.5	19.8	
10:30			95	70	30	1179	638	60	78	78.5	19.7	Pulled Filtrate Sample
10:45			93	70	30	1178	639	60	78	78.5	19.3	
11:00			93	70	30	1178	639	60	78	78.5	19.3	
11:10			96	70	30	1181	635	60	78	78.5	19.7	12.55 KW
11:45			93	70	30	1178	639	60	78	78.5	19.7	
12:00			93	70	30	1178	635	60	78	78.5	19.7	
12:15			96	70	30	1181	631	60	78	78.5	19.3	
12:30			96	70	30	1181	639	60	78	78.5	19.8	
12:45			96	70	30	1181	639	60	78	78.5	19.8	
13:00			96	70	30	1181	631	60	78	78.5	18.3	
13:30			96	70	30	1181	630	60	78	78.5	19.1	
13:45			96	70	30	1180	639	60	78	78.5	19.0	
14:00			96	70	30	1180	638	60	78	78.5	19.6	
14:15			96	70	30	1179	633	60	78	78.5	19.1	
14:30			96	70	30	1179	637	60	78	78.5	19.2	Pulled Filtrate Sample
14:45			96	70	30	1180	638	60	78	78.5	19.2	
14:50			96	70	30	1180	638	60	78	78.5	19.1	
15:00			96	70	30	1180	638	60	78	78.5	19.1	
15:15			96	70	30	1180	638	60	78	78.5	19.1	
15:30			96	70	30	1179	639	60	78	78.5	19.7	
16:07			96	70	30	1180	639	60	78	78.5	19.7	
16:50			95	70	30	1138	626	60	78	100	17.3	
17:31			95	70	30	1139	615	60	78	98.5	14.3	
18:18			95	70	30	1137	618	60	78	98.5	14.7	

25 Disk Rotary Filter Data Sheet														
Date:	Tank Level (gal)		Solids Loading (wt %)	Temp (F)	Core Press PG-1 (PSI)	Filtrate Press PG-2 (PSI)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments	Recorded by
1/10	65	1.29	67	70	30	30	145	5.63	60	68	70.5	20.0	13.46 KIL	BYE
1/20				95	70	30	1169	5.89	60	87	70.5	14.1	13.67 KIL	BYE
1/21				94	70	30	1138	5.95	60	96	70.5	14.8	13.94 KIL	BYE
1/24				94	70	30	1161	7.84	60	96	70.5	14.1	12.53 KIL	BYE
1/22				94	70	30	1139	6.01	60	95.5	70.5	14.7	17.55 KIL	BYE
1/15				95	70	30	1170	5.87	60	98	70.5	18.8	diller to 64.7 s-p4 filter diller	BYE
1/38				92	70	30	1184	5.93	60	98.5	70.5	18.5		BYE

25 Disk Rotary Filter Data Sheet												
Date:	2-21-08											
Time (h:mm)	Tank Level (gal)	Solids Loading (wt %)	Tamp (F)	Conc. Press PG-1 (PSI)	Filtrate Press PG-2 (PSI)	Feed Flow (mA)	Filtrate Flow (mA)	Rotor Speed (Hz)	Seal Temp (F)	Rotary Joint Temp (F)	Motor Current (amps)	Comments
1335	600	1.79	96	70	30	11.83	5.52	60	66.8	72.5	19.6	Started Run
1343						11.83	5.71		77.5	86.5	19.7	
1350						11.79	5.51		84.3	90.8	19.7	
1350						11.77	5.56		94.0	91.5	19.4	
1350						11.79	5.49		93.0	92.3	19.2	
1359						11.70	5.95		96.5	95.0	19.2	
1400						11.54	5.55		95.4	94.0	19.1	
1413						11.90	5.34		95.0	96.0	19.1	
1430						11.54	5.58		96.8	94.9	19.1	
1445						11.54	5.58		96.8	94.9	19.1	
1500						11.54	5.97		97.5	95.0	19.1	
1515						11.73	5.53		94.3	94.5	19.1	
1626						11.91	5.53		94	101.5	19.1	
1645						11.36	5.86		92	102.5	19.0	
1739						11.77	5.73		98	99.5	19.0	

Pulled Filtrate Sample



Appendix B: Solid Particles

